

6.0 CE COMPLIANT INSTALLATION REQUIREMENTS AND INFORMATION

In order to reduce the amount of radiated Electro-Magnetic Interference and to reduce the susceptibility of the drive to interference from other devices the drive should be installed in accordance with the following instructions:

- 1) All Power and control wiring entering or leaving the enclosure must be enclosed in flexible metal conduits terminated with metal grounding hoods at each end.

- 2) A power line input filter Corcom Type 10VVI or equivalent must be installed at the power input of the drive with good electrical bonding to the wall of the enclosure.

The drive was installed by following the above instruction and was tested in an independent laboratory. The drive was found to be in conformance with the CE EMC directive but there is no guarantee that these findings can be transferred to a particular drive in a specific installation.

BRONCO DC 160 SERIES DRIVES, TYPICAL

